



NOTES:

1. GRIND EXISTING PAVEMENT TO NEAT EDGE MINIMUM 20" WIDE.
2. CONTRACTOR SHALL ADJUST HORIZONTAL TRENCH ALIGNMENT TO AVOID EXISTING UTILITIES AS NECESSARY. VERIFY ALIGNMENT ADJUSTMENTS WITH CITY REPRESENTATIVE. MAINTAIN MIN 12" CLEARANCE FROM EXISTING UTILITIES AND OBSTRUCTIONS.
3. FOR ITS CONDUIT TRENCH DETAIL, SEE STD DWG ITS-4 AND ITS-5.
4. REPAVING OPERATIONS SHALL BE TO CITY STD SPECS AND DRAWINGS.